



August 22, 2007

Louisiana-Pacific Corporation
2706 US Highway 421 North
Wilmington, NC 28401

Attention: Mr. Ping Cheng, P.E.
Research Engineer

Dear Sir:

Re: Evaluation No. 3131125COQ-001
Use of RSIC-1 Clip in One-Hour Rated Louisiana-Pacific Floor/Ceiling Assemblies

The PAC International Inc. Type RSIC-1 is a resilient furring channel mounting clip system intended to improve STC ratings. It is listed by UL for use in the following wood-framed floor/ceiling assemblies:

Design Nos.: L502, L505, L510-L514, L518, L521, L523, L528, L532, L534, L542, L546, L547, L548, L550, L562, L569, L570, L573, L576, L579, L582, and L589

The L-P floor/ceiling assemblies listed by Intertek are similar to the equivalent UL listed designs but use L-P structural members. The use of the PAC International Inc. RSIC-1 clip system will not reduce the fire resistance rating of the Louisiana-Pacific 45-minute and 60-minute floor/ceiling assemblies.

The RSIC-1 clip may be used in the LP/FCA 45-01 and LP/FCA 60-01 Intertek listed floor/ceiling assemblies.

Yours truly,

INTERTEK TESTING SERVICES NA LTD.

Michael van Geyn, A.Sc.T.
Manager – Fire Testing & Technical Programs

MVG/bjm

C:\Documents and Settings\bills\My Documents\ITS-DATA\490-WP\RPT\2007 - 491 Rpts\LP-3131125.aug-07.doc

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

